

O/o. E.D. (EITC)
CSPDCL Raipur

Receipt No. 5752

Date 10 DEC 2018

AGM(IT)

SE (O)/SE

EE

Section



CHHATTISGARH STATE POWER TRANSMISSION COMPANY LTD.

(A Government of Chhattisgarh Undertaking)

OFFICE OF THE EXECUTIVE DIRECTOR (S/s O&M)

e-mail : ce_tnc@yahoo.com, Fax : 0771-2574267, CIN-U40108CT2003SGC015820

No. 02/07/SE/ 2137

Raipur, Dated : 10/12/2018

AMM
10/12/18

To,
The Executive Director (EITC)
CSPDCL, Raipur.

Sub:- Monthly report of tripping of 33KV Industrial Feeders.
Ref. :- CE (RA&PM) CSPDCL, Raipur letter no. 1195 dtd. 26.07.2018.

---00---

Vide above referred letter CE (RA&PM) CSPDCL, Raipur conveyed that under Ease of Doing Business it is required to publish the monthly data regarding total duration of frequency of power outage of Industrial feeders online in public domain. In compliance of that tripping of 33KV Industrial feeders for the month of November-2018 is submitted.

Kindly arrange to upload the data in public domain in the website of CSPTCL/ CSPDCL.

Encl:- Tripping report of 33KV Industrial feeder for the month of November-2018.

Executive Director (S/s-O&M)
CSPTCL, Raipur

Copy to:

The Chief Engineer (RA&PM) CSPDCL, Raipur for information.

Information pertains to Tripping Details of 33 KV Industrial feeders radiating from EHV S/s of CSPTCL in the CG State for the month of November-2018.


Name of Circle - Bhilai		Name of Division -SS Dn., Bhilai		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder,	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
1	132 KV S/S Bhilai	Chhouni Ind.-III	0	0:00
		Simplex	1	0:03
		Industrial	0	0:00
		Chhouni Industrial-II	0	0:00
		Niros Industrial	1	0:03
		Kumhari Ind.	1	0:03
2	132 KV S/S Kurud	33 KV Kurud Ind.	1	0:21
		33 KV Nandani Road Ind.	3	0:14
3	132KV S/S Ruabandha	33KV Baghera feeder	1	0:03
4	132KV S/S Dhamdha	33KV PGCIL	6	0:18
Total			14	1:05:00

Name of Circle - Bhilai		Name of Division -SS Dn., Rajnandgaon		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
1	132 KV S/S Rajnandgaon	33 KV DURG-I	1	0:03
		33 KV SAI CHEMICAL	4	0:12
		33KV INDUSTRIAL	5	0:15
2	132KV S/s Dongargaon	33 KV TUMDIBOD	4	0:12
		33 KV INDUSTRIAL	2	0:06
3	132KV S/S Dallirajhara	33 KV BSP NO-I	0	0:00
		33 KV BSP NO-II	1	0:05
	132KV S/S Rasmada	33 KV RASMADA-I	1	0:03
		33 KV RASMADA-II	4	0:13
		33 KV RASMADA-III	45	6:08
5	132KV S/s Kawardha	33KV Ramhepur	1	0:03
6	132KV S/s Pandariya	33KV SugarFactory	1	5:30
Total			69	12:50:00

Name of Circle - Raipur		Name of Division -SS Dn.-I		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
1	220 KV Urla	Shyama	3	2:55
2		C-I	2	0:11
3		URLA-I FEEDER	2	2:03
4		URLA-II FEEDER	3	0:25
5		KABEER NAGAR FEEDER	1	0:40
6		SARORA FEEDER	0	0:00
7		PANKAJ FEEDER	0	0:00
8		HIRA FEEDER	4	1:47
9		INABA FEEDER	1	0:11
10		ALOK FEEDER	1	0:16
11	132 KV Gudhiyari	PIL	2	0:12
12		Biragaon I/C (Out going)	2	0:12
13	132 KV Borjhara	Atari (Out going)	4	0:15
14		Shilpi	3	0:10
15		New Kabir Nagar (Out going)	4	0:15
16		Alankar	6	0:19
17		Balaji	1	0:20
18		Omikiran	10	4:08
19		Alloy	3	0:39

20	132 KV Sector 'C'	BHAVANI FEEDER	1	0:15
21		CHHATTISGARH FEEDER	3	0:30
22		R.NARAYAN FEEDER	1	0:15
23		INDSIL FEEDER	2	1:50
24		RAGHUVIR FEEDER *	2	0:15
25		AVINASH FEEDER	2	0:50
26		VANDANA FEEDER	2	0:45
27		RATU SARIYA FEEDER	0	0:00
28		Prakash	0	0:00
29	220/132 KV S/s Siltara	33KV Bhagwati power	1	2:08
30		33 KV Baldev	0	0:00
31		33KV Devi Iron	2	7:45
32		33 KV Indian Oil	4	7:07
33		33 KV Jorawar	0	0:00
34		33 KV Aster	1	0:30
35		33 KV C.G. Ispat	1	1:57
36		Bus Coupler Feeder	0	0:00
37		33 KV Hanuman	0	0:00
38		33KV Nandan	0	0:00
39		33KV Mahindra	0	0:00
40		33KV Gagan	2	2:05
41		33 KV New Droliya	0	0:00
42		33KV Europratik	4	4:25
43		33KV Cyclepark	0	0:00
44		33KV Rashmi	1	4:45
45		33KV Shyam Iron	2	1:25
46		33 KV API	1	17:35
47		33 KV G.R. Sponge	2	2:16
48		33KV S.K. Sarwangi	0	0:00
49		33KV Gopal	0	0:00
50		33KV Waswani	0	0:00
51		33 KV Su0 Ispat	5	3:54
52		33KV Droliya cable	1	2:10
53		33 KV Ghankun	0	0:00
54	132 KV Hira pooling	RR ISPAT FEEDER	0	0:00
55		METAL PARK FEEDER	0	0:00
56		GRAVITY FEEDER	0	0:00
57		VENKATESHWAR FEEDER	1	0:22
58		ROTOCOST FEEDER	0	0:00
59	SAURABH FEEDER	1	0:15	
60	132 KV Birgaon	SIMGA FEEDER	0	0:00
61		SILTARA FEEDER	1	0:25
62		Mahesh	0	0:00
63		AIR FEEDER	0	0:00
64		RAIPUR INTER CONN.	0	0:00
65		URLA -I FEEDER	3	1:40
66		HTC-III FEEDER	2	1:55
67		SIMPLEX FEEDER	2	0:22
68		HTC-II FEEDER	2	0:55
69		URLA-II FEEDER	1	0:20
70		HTC-I FEEDER	9	8:20
71		Biragaon-Mandir hausad	2	0:10
72	132 KV Tulsi	HT Feeder (Tulsi)	3	0:12
		Total	119	92:36:00

Industrial feeder trippings for November-2018 Total	202	106:31:00
--	------------	------------------


 Executive Engineer
 C/O ED (S/O & M)
 C.S.P. Trans. S.L. RAIPUR