

No.02-07/SE/ 2167

Raipur, Dated : 10/01/2020

To,
The Executive Director (EITC)
CSPDCL, Raipur.

Sub:- Monthly report of tripping of 33KV Industrial Feeders.


Ref. :- CE (RA&PM) CSPDCL, Raipur letter no. 1195 dtd. 26.07.2018.

---00---

Vide above referred letter, CE (RA&PM) CSPDCL, Raipur has intimated that under Ease of Doing Business, monthly data regarding total duration & frequency of power outage of Industrial feeders is required to be published on public domain. In compliance, tripping details of 33KV Industrial feeders for the month of December-2019 is submitted.

Kindly arrange to upload the data on public domain in the website of CSPTCL/ CSPDCL.

Encl:- Tripping report of 33KV Industrial feeder for the month of December-2019.


10/1
Chief Engineer (S/s-O&M)
CSPTCL, Raipur

Copy to:

The Chief Engineer (RA&PM) CSPDCL, Raipur for information.

Information pertains to Tripping Details of 33 KV Industrial feeders radiating from EHV S/s of CSPTCL in the CG State for the month of December -2019.

Name of Circle - Bhilai		Name of Division -SS Dn., Bhilai		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
1	132 KV S/S Bhilai	Chhouni Industrial-III	1	0:26:00
		Simplex	1	0:27:00
		Industrial	1	0:48:00
		Chhouni Industrial-II	5	1:17:00
		Niros Industrial	5	3:42:00
		Kumhari Ind.	6	0:20:00
2	132 KV S/S Kurud	Kurud Ind.	NIL	0:00:00
		Nandani Road Ind.	NIL	0:00:00
3	132KV S/S Ruabandha	Baghera feeder	NIL	0:00:00
4	132KV S/S Dhamdha	PGCIL	3	0:09:00

Name of Circle - Bhilai		Name of Division -S/S Dn., Rajnandgaon		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
1	132KV S/S Rajnandgaon	Durg-I	4	0:12:00
		Sai chemical	2	0:06:00
		Industrial	10	1:36:00
2	132KV S/s Dongargaon	Tumdibod	10	0:30:00
		Industrial	8	0:24:00
3	132KV S/S Dallirajhara	BSP No.-I	1	0:03:00
		BSP No.-II	2	0:06:00
	132KV S/S Rasmada	Rasmada-I	1	0:08:00
Rasmada-II		1	0:06:00	
Rasmada-III		0	0:00:00	
5	132KV S/s Kawardha	Ramhepur	1	0:03:00
6	132KV S/s Pandariya	Sugar Factory	3	3:15:00


Name of Circle - Raipur		Name of Division -SS Dn.-I		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
1	220 KV Urla	Shyama	1	0:05:00
2		C-I	4	0:15:00
3		Urla-I Feeder	4	0:48:00
4		Urla-II Feeder	4	0:46:00
5		Kabeer Nagar Feeder	6	5:25:00
6		Sarora Feeder	3	4:00:00
7		Pankaj Feeder	1	2:28:00
8		Hira Feeder	NIL	0:00:00
9		Inaba Feeder	2	0:15:00
10		Alok Feeder	6	4:26:00
11		Patharidih	1	0:18:00
12	132 KV Gudhiyari	PIL	4	6:50:00
13		Biragaon I/C (Out going)	NIL	0:00:00

Information pertains to Tripping Details of 33 KV Industrial feeders radiating from EHV S/s of CSPTCL in the CG State for the month of December -2019.

Name of Circle - Bhilai		Name of Division -SS Dn., Bhilai		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
14	132 KV Borjhara	Atari (Out going)	2	0:10:00
15		Shilpi	NIL	0:00:00
16		New Kabir Nagar (Out going)	2	0:11:00
17		Alankar	7	0:21:00
18		Balaji	8	2:26:00
19		Omikiran	3	0:51:00
20		Alloy	2	0:10:00
21	132 KV Sector 'C'	Bhavani Feeder	NIL	0:00:00
22		Chhattisgarh Feeder	4	0:28:00
23		R. Narayan Feeder	12	9:22:00
24		Insdil Feeder	NIL	0:00:00
25		Raghuvir Feeder	3	1:13:00
26		Avinash Feeder	5	7:55:00
27		Vandana Feeder	1	1:15:00
28		Ratu Sariya Feeder	2	2:10:00
29		Prakash	1	0:10:00
30	220/132 KV S/s Siltara	Bhagwati power	NIL	0:00:00
31		Baldev	1	5:40:00
32		Devi Iron	NIL	0:00:00
33		Indian Oil	3	8:59:00
34		Jorawar	NIL	0:00:00
35		Aster	1	1:54:00
36		C.G. Ispat	8	15:05:00
37		Bus Coupler Feeder	NIL	0:00:00
38		Hanuman	1	0:55:00
39		Nandan	1	4:18:00
40		Mahindra	3	18:56:00
41		Gagan	7	10:20:00
42		New Droliya	NIL	0:00:00
43		Europratik	Disconnected	Disconnected
44		Cyclepark	1	0:34:00
45		Rashmi	3	10:28:00
46		Shyam Iron	1	1:10:00
47		API	NIL	0:00:00
48		G.R. Sponge	1	0:08:00
49		S.K. Sarwangi	NIL	0:00:00
50		Gopal Sponge	NIL	0:00:00
51		Waswani	1	3:05:00
52		Sunil Ispat	5	31:27:00
53		Droliya cable	1	5:08:00
54	Ghankun	NIL	0:00:00	

Information pertains to Tripping Details of 33 KV Industrial feeders radiating from EHV S/s of CSPTCL in the CG State for the month of December -2019.

Name of Circle - Bhilai		Name of Division -SS Dn., Bhilai		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
55	132 KV Hira pooling	RR Ispat	NIL	0:00:00
56		Metal Park	1	1:57:00
57		Gravity	NIL	0:00:00
58		Venkateshwar	1	1:02:00
59		Rotocost	1	1:28:00
60		Saurabh	NIL	0:00:00
61		132 KV Birgaon	Simga	5
62	Siltara		14	13:21:00
63	Mahesh		3	0:31:00
64	AIR		2	0:16:00
65	Raipur Inter Conn.		6	1:19:00
66	Urla-I		NIL	0:00:00
67	HTC-III		3	1:59:00
68	Simplex		4	3:42:00
69	HTC-II		3	1:02:00
70	Urla-II		3	2:53:00
71	HTC-I		2	0:55:00
72	Biragaon-Mandir hausad	2	0:13:00	
73	132 KV Tulsi	HT (Tulsi)	1	0:05:00


Executive Engineer
O/o Chief Engineer (S/s-O&M)
CSPTCL, Raipur