

**CHHATTISGARH STATE POWER TRANSMISSION COMPANY LTD.**

(A Government of Chhattisgarh Undertaking)

**OFFICE OF THE EXECUTIVE DIRECTOR (S/s O&M) RAIPUR**

e-mail : ce\_tnc@yahoo.com, Fax : 0771-2574267, CIN-U40108CT2003SGC015820

No.02-07/SE/Inds.Fdr./ 826

Raipur, Dated : 13/08/2020

To,  
The Executive Director (EITC)  
CSPDCL, Raipur.

Sub:- Monthly report of tripping of 33KV Industrial Feeders.


Ref. :- CE (RA&PM) CSPDCL, Raipur letter no. 1195 dtd. 26.07.2018.

---00---

Vide above referred letter, CE (RA&PM) CSPDCL, Raipur has intimated that under Ease of Doing Business, monthly data regarding total duration & frequency of power outage of Industrial feeders is required to be published on public domain. In compliance, tripping details of 33KV Industrial feeders for the month of July-2020 is submitted.

Kindly arrange to upload the data on public domain in the website of CSPTCL/ CSPDCL.

Encl:- Tripping report of 33KV Industrial feeder for the month of July-2020.

  
**Executive Director (S/s-O&M)**  
**CSPTCL, Raipur**

**Copy to:**

The Chief Engineer (RA&PM) CSPDCL, Raipur for information.

**Information pertains to Tripping Details of 33 KV Industrial feeders radiating from EHV S/s of CSPTCL in the CG State for the month of July -2020.**

Name of Circle - Bhilai		Name of Division -S/S Dn., Bhilai		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
1	132 KV S/S Bhilai	Chhouni Industrial-III	1	0:03:00
		Simplex	4	1:35:00
		Industrial	6	0:19:00
		Chhouni Industrial-II	6	5:38:00
		Niros Industrial	4	3:26:00
		Kumhari Ind.	6	0:30:00
2	132 KV S/S Kurud	Kurud Ind.	2	0:07:00
		Nandani Road Ind.	9	1:43:00
3	132KV S/S Ruabandha	Baghera feeder	7	0:50:00
4	132KV S/S Dhamdha	PGCIL	6	0:18:00

Name of Circle - Bhilai		Name of Division -S/S Dn., Rajnandgaon		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
1	132KV S/S Rajnandgaon	Durg-I	11	0:33:00
		Sai chemical	25	7:53:00
		Industrial	10	1:37:00
2	132KV S/s Dongargaon	Tumdibod	13	0:39:00
		Industrial	23	1:53:00
3	132KV S/S Dallirajhara	BSP No.-I	2	0:08:00
		BSP No.-II	1	0:03:00
	132KV S/S Rasmada	Rasmada-I	3	3:15:00
Rasmada-II		Nil	0:00:00	
Rasmada-III		2	3:15:00	
5	132KV S/s Kawardha	Ramhepur	Nil	0:00:00
6	132KV S/s Pandariya	Sugar Factory	3	0:15:00


Name of Circle - Raipur		Name of Division -SS Dn.-I		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
1	220 KV Urla	Shyama	Nil	0:00:00
2		C-I	1	0:09:00
3		Urla-I	1	0:26:00
4		Urla-II	6	0:30:00
5		Kabeer Nagar	1	0:09:00
6		Sarora	1	0:10:00
7		Pankaj	1	8:37:00
8		Hira	3	2:15:00
9		Inaba	7	3:47:00
10		Alok	1	0:10:00
11		Patharidih	8	3:50:00

**Information pertains to Tripping Details of 33 KV Industrial feeders radiating from EHV S/s of CSPTCL in the CG State for the month of July -2020.**

Name of Circle - Bhilai		Name of Division -S/S Dn., Bhilai		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
12	132 KV Gudhiyari	PIL	1	0:05:00
13		Biragaon I/C (Out going)	6	0:23:00
14	132 KV Borjhara	Atari (Out going)	15	3:57:00
15		Shilpi	2	0:07:00
16		New Kabir Nagar (Out going)	9	3:56:00
17		Alankar	3	0:31:00
18		Balaji	6	1:33:00
19		Omkiran	4	3:52:00
20		Alloy	Nil	0:00:00
21		132 KV Sector 'C'	Bhavani	1
22	Chhattisgarh		5	3:10:00
23	R. Narayan		2	0:36:00
24	Insdil		1	0:10:00
25	Raghuvir		2	0:20:00
26	Avinash		1	1:00:00
27	Vandana		1	1:55:00
28	Ratu Sariya		6	4:20:00
29	Prakash		Nil	0:00:00
30	220/132 KV S/s Siltara	Bhagwati power	3	97:20:00
31		Baldev	1	2:51:00
32		Devi Iron	1	4:50:00
33		Indian Oil	2	1:49:00
34		Jorawar	2	3:10:00
35		Aster	Nil	0:00:00
36		C.G. Ispat	3	3:25:00
37		Bus Coupler	Nil	0:00:00
38		Hanuman	4	3:08:00
39		Nandan	1	1:51:00
40		Mahindra	1	4:00:00
41		Gagan	8	10:08:00
42		New Droliya	1	0:25:00
43		Europratik	Disconnected	Disconnected
44		Cyclepark	3	2:50:00
45		Rashmi	5	11:42:00
46		Shyam Iron	Nil	0:00:00
47		API	Nil	0:00:00
48		G.R. Sponge	Nil	0:00:00
49		S.K. Sarwangi	1	3:44:00
50		Gopal Sponge	Nil	0:00:00
51		Waswani	1	11:15:00
52		Sunil Ispat	Nil	0:00:00
53		Droliya cable	Nil	0:00:00
54	Ghankun	Nil	0:00:00	

**Information pertains to Tripping Details of 33 KV Industrial feeders radiating from EHV S/s of CSPTCL in the CG State for the month of July -2020.**

Name of Circle - Bhilai		Name of Division -S/S Dn., Bhilai		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
55	132 KV Hira pooling	RR Ispat	1	0:18:00
56		Metal Park	1	1:50:00
57		Gravity	1	1:50:00
58		Venkateshwar	2	2:22:00
59		Rotocost	3	1:55:00
60		Saurabh	3	3:08:00
61	132 KV Birgaon	Simga	8	3:04:00
62		Siltara	5	7:49:00
63		Mahesh	4	1:11:00
64		AIR	1	0:05:00
65		Raipur Inter Conn.	7	1:26:00
66		Urla-I	3	0:29:00
67		HTC-III	2	1:50:00
68		Simplex	Nil	0:00:00
69		HTC-II	5	4:25:00
70		Urla-II	9	7:18:00
71		HTC-I	5	5:00:00
72		Biragaon-Mandir hausad	5	1:19:00
73	132 KV Tulsi	HT (Tulsi)	13	0:58:00

  
 Executive Engineer  
 O/o Executive Director (S/s-O&M)  
 CSPTCL, Raipur