

CHHATTISGARH STATE POWER TRANSMISSION COMPANY LTD.

(A Government of Chhattisgarh Undertaking)

OFFICE OF THE EXECUTIVE DIRECTOR (S/s O&M)

e-mail : ce_tnc@yahoo.com, Fax : 0771-2574267, CIN-U40108CT2003SGC015820

No.02-07/SE/ 654

Raipur, Dated 24/06/2019

To,
The Executive Director (EITC)
CSPDCL, Raipur.

Sub:- Monthly report of tripping of 33KV Industrial Feeders.


Ref. :- CE (RA&PM) CSPDCL, Raipur letter no. 1195 dtd. 26.07.2018.

---00---

Vide above referred letter, CE (RA&PM) CSPDCL, Raipur has intimated that under Ease of Doing Business, monthly data regarding total duration & frequency of power outage of Industrial feeders is required to be published on public domain. In compliance, tripping details of 33KV Industrial feeders for the month of May-2019 is submitted.

Kindly arrange to upload the data on public domain in the website of CSPTCL/ CSPDCL.

Encl:- Tripping report of 33KV Industrial feeder for the month of May -2019.


Executive Director (S/s-O&M)
CSPTCL, Raipur

Copy to:

The Chief Engineer (RA&PM) CSPDCL, Raipur for information.

Information pertains to Tripping Details of 33 KV Industrial feeders radiating from EHV S/s of CSPTCL in the CG State for the month of May -2019.


Name of Circle - Bhilai		Name of Division -SS Dn., Bhilai		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
1	132 KV S/S Bhilai	Chhouni Ind.-III	3	6:45
		Simplex	1	0:25
		Industrial	3	2:38
		Chhouni Industrial-II	2	1:22
		Niros Industrial	0	0:00
		Kumhari Ind.	8	1:37
2	132 KV S/S Kurud	33 KV Kurud Ind.	3	0:10
		33 KV Nandani Road Ind.	1	0:03
3	132KV S/S Ruabandha	33KV Baghera feeder	12	7:37
4	132KV S/S Dhamdha	33KV PGCIL	3	0:09

Name of Circle - Bhilai		Name of Division -SS Dn., Rajnandgaon		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
1	132 KV S/S Rajnandgaon	33 KV DURG-I	15	0:45
		33 KV SAI CHEMICAL	17	0:51
		33KV INDUSTRIAL	8	0:24
2	132KV S/s Dongargaon	33 KV TUMDIBOD	5	0:39
		33 KV INDUSTRIAL	1	0:05
3	132KV S/S Dallirajhara	33 KV BSP NO-I	2	0:29
		33 KV BSP NO-II	5	1:44
	132KV S/S Rasmada	33 KV RASMADA-I	1	0:35
33 KV RASMADA-II		0	0:00	
33 KV RASMADA-III		12	1:37	
5	132KV S/s Kawardha	33KV Ramhepur	1	0:03
6	132KV S/s Pandariya	33KV SugarFactory	1	0:05

Name of Circle - Raipur		Name of Division -SS Dn.-I		
S.no.	Name of 220/132KV S/s in which feeder emanating	Name of 33 KV feeder	Total no. of Tripping/Breakdown	Total outage in Hrs.:Min
1	220 KV Urla	Shyama	7	5:16
2		C-I	7	7:55
3		URLA-I FEEDER	6	2:37
4		URLA-II FEEDER	9	0:43
5		KABEER NAGAR FEEDER	2	5:23
6		SARORA FEEDER	3	5:27
7		PANKAJ FEEDER	9	8:26
8		HIRA FEEDER	3	6:38
9		INABA FEEDER	4	6:23
10		ALOK FEEDER	7	13:29
11	132 KV Gudhiyari	PIL	1	0:31
12		Biragaon I/C (Out going)	5	0:54
13		Atari (Out going)	5	1:02
14		Shilpi	1	0:35
15		New Kabir Nagar (Out going)	4	1:33

16	132 KV Borjhara	Alankar	6	0:55
17		Balaji	10	4:27
18		Omkiran	6	3:00
19		Alloy	2	0:39
20	132 KV Sector 'C'	BHAVANI FEEDER	1	1:20
21		CHHATTISGARH FEEDER	3	2:04
22		R.NARAYAN FEEDER	3	3:44
23		INDSIL FEEDER	1	1:20
24		RAGHUVIR FEEDER	7	3:15
25		AVINASH FEEDER	3	3:25
26		VANDANA FEEDER	2	2:35
27		RATU SARIYA FEEDER	5	3:59
28		Prakash	1	1:20
29	220/132 KV S/s Siltara	33KV Bhagwati power	0	0:00
30		33 KV Baldev	0	0:00
31		33KV Devi Iron	1	6:35
32		33 KV Indian Oil	2	1:35
33		33 KV Jorawar	3	7:11
34		33 KV Aster	2	0:43
35		33 KV C.G. Ispat	0	0:00
36		Bus Coupler Feeder	0	0:00
37		33 KV Hanuman	4	7:37
38		33KV Nandan	1	0:20
39		33KV Mahindra	0	0:00
40		33KV Gagan	5	7:53
41		33 KV New Droliya	Disconnected	
42		33KV Europratik	Disconnected	
43		33KV Cyclepark	1	1:38
44		33KV Rashmi	2	43:18
45		33KV Shyam Iron	1	1:23
46		33 KV API	1	13:20
47		33 KV G.R. Sponge	3	6:34
48		33KV S.K. Sarwangi	1	0:30
49	33KV Gopal	1	1:38	
50	33KV Waswani	0	0:00	
51	33 KV Sunil spat	0	0:00	
52	33KV Droliya cable	12	10:23	
53	33 KV Ghankun	3	18:44	
54	132 KV Hira pooling	RR ISPAT FEEDER	4	9:24
55		METAL PARK FEEDER	1	1:13
56		GRAVITY FEEDER	3	0:36
57		VENKATESHWAR FEEDER	1	6:22
58		ROTOCOST FEEDER	1	46:41
59		SAURABH FEEDER	2	0:42
60		SIMGA FEEDER	1	0:44
61		SILTARA FEEDER	7	3:33
62		Mahesh	4	36:01
63		AIR FEEDER	7	1:47
64		RAIPUR INTER CONN.	10	3:09

65	132 KV Birgaon	URLA -I FEEDER	3	0:44
66		HTC-III FEEDER	3	7:53
67		SIMPLEX FEEDER	0	0:00
68		HTC-II FEEDER	11	24:10
69		URLA-II FEEDER	3	2:19
70		HTC-I FEEDER	4	7:21
71		Birgaon-Mandir hausad	8	3:13
72	132 KV Tulsi	HT Feeder (Tulsi)	1	0:03


Executive Engineer
O/o Executive Director (S/s-O&M)
CSPTCL, Raipur